

# Certificate of Analysis

# Micro Technology

has been analyzed for compliance with the air/gas quality portion of the specification:

ISO 8573-1:2010

as reported on this certificate for the sample described below.

Results relate only to items tested. This report shall not be reproduced except in full without the written permission of Trace Analytics, LLC Copyright ©2024 Trace Analytics, LLC

Maria Sandoval, Laboratory Director

#### Results vs ISO 8573-1:2010

	Limiting Characteristics	Purity Class (B)	Sample Results (3)	Specification Limit	Pass / Fail	Estimate of Uncertainty % (1)	
	Maximum Number of Particles per	$0.1 < d \le 0.5 \mu m$		(A)			
	Cubic Meter (m3) as a Function of Particles Size, d,	$0.5 < d \le 1.0  \mu m$	(D)	5679			±19
Particles		$1.0 < d \le 5.0 \mu m$		3743			±19
	in micrometers (μm)	d > 5.0 μm		Detected			
	By Mass Concentration (CP), mg/m <sup>3</sup>	6	< 0.048	≤5	PASS	±4.3	
Water	Pressure Dew Point, °C	(W)	>-12		N/D	±30	
	Oil Aerosol, mg/m³		< 0.048			±4.6	
0il	Oil Vapor, mg/m³		< 0.004			±6.3	
	Total Oil, mg/m³	2	< 0.052	≤0.1	PASS	±10.9	
	Other Vapors, mg/m³ (O4), comprise						
	Cyclotrisiloxane, hexamethyl- (32)		0.074			±6.3	
	Silicic acid, diethyl bis(trimethylsil		0.058			±6.3	
Other (2)							
01.101 (2)							

# Sampling Point Identification

Collection Point: Main Drop Purification: Refrigerated Dryer Sampling Schedule: Annual

Next Sample Due Approx: 8/14/2025



# Report 24-27192

# Contact (4) \*

To: MICRO TECHNOLOGY 1819 FIRMAN DRIVE #137 RICHARDSON. TX 75081 Customer ID: 93786
Purchase Order: 70065202

Sample Date: Wed, Aug 14, 2024

Sampled By: Fred Beckhusen
Sampled For: Micro Technology

**Received:** Wed, Aug 21, 2024 **Analyzed:** Tue, Aug 27, 2024

**Reported:** Tue, Aug 27, 2024

**Customer Comments:** 

Sampling Point Identification:

Collection Point: Main Drop Purification: Refrigerated Dryer

# Specification Notes

analyzed, and reported) and can affect the validity of results.

Results Notes

n/a = not applicable

(A) By agreement between the customer and laboratory, this report does not include  $0.1\text{-}0.5~\mu m$  particles.

n/d = not determined n/p = not provided n/s = not specified

indicates <LOQ, Tr = Trace, >LOD & LOQ (1) At the 95% confidence interval as a percent of the specification

limit includes sampling and analytical estimates of uncertainty. Measurement uncertainty is not taken into account when reporting Pass/Fail designations. (2) Gases named in ISO 8573-6 Table 2 and/or other

measurands required by the specification or customer. (3) Results apply to the sample as received from the customer. (4) Information supplied by the customer is designated by an asterisk (except dates received,

(B) For a "baseline" sample, the most restrictive class that the sample passes was selected. (D) Particles of size d  $> 5.0 \, \mu m$  were detected. Particle classes 1-5 may not be employed according to ISO 8573-1. The particles had a maximum size of 10  $\mu m$  and the following appearance: irregularly shaped particles dark gray/black in color.

#### **Laboratory Notes**

(O4) Other compounds that are not Oil Vapor were detected and may be considered Organic Solvents. The first number in parentheses indicates the goodness of fit of the sample mass spectrum to the NIST library, with 100 being complete agreement.

(W) Pressure dew point was calculated based on the 20/a-P tube. When both tubes are used, the results with an air volume nearer the recommended volume are used. The 5/a-P tube reading resulted in a calculated pressure dew point of >19°C. The water vapor detector tube reading was greater than the highest point on the scale. Water Class and Pass/Fail cannot be determined because the true value is unknown.

### System Information \*

.,		
Comp Make	Filter Make	
Comp Model	Dryer Make	
Comp Serial		

Sampling Collection Conditions *				Sampling Collection Information *							
	Temperat	ure P	ressure	Parameter	Media No.	Flow Rate (L / min)	Sampling Time	Blank		For Detector Tubes O	Scale
Sampling Point	n/p		80 psig	Aerosol (Particles & Oil Aerosol)	671626	50	10 : 02				
Ambient	75°F	2	9.9 in Hga	Water Vapor	5/a-P (6728531)	4	0:60		>	200 mg/m <sup>3</sup>	200
Flowmeter Calibration Information *		(Pressure Dew Point)	20/a-P (8103061)	4	10:00		>	500 mg/m <sup>3</sup>	500		
			Calibration Due	Sulfur Dioxide, SO <sub>2</sub>	0.5/a-P (6728491)					ppmv	
Flowmeter Type				Nitrogen Oxides, NO <sub>x</sub>	0.5/a-P (CH29401)					ppmv	
Filter Flowmeter				Oil Vapor	971292	4	10:00	970901			
Tube Flowmeter				CO, CO <sub>2</sub> , HC							

NOTE: Blank fields indicate that samples were not obtained for the given limiting characteristic and no analytical results are presented.

#### **Analytical Methods**

Test Method	Contaminant	Sampling Technique	Analytical Technique	Accredited
CAT-A-01	Gases (CO, CO <sub>2</sub> , HC)	Gas Collection Bottle	Gas Chromatography - MS / FID	Yes
CAT-A-03	Particles by Mass	Membrane Filter (0.2 μm)	Gravimetry	Yes
CAT-A-03	Oil Aerosol	Membrane Filter (0.2 μm)	Extraction - Gravimetry	Yes
CAT-A-04	Particles by Size	Membrane Filter (0.2 μm)	Optical Microscopy	Yes
CAT-A-06	Oil Vapor	Charcoal Tube	Gas Chromatography - Mass Spectrometry	Yes
CAT-A-07	Pressure Dewpoint, SO <sub>2</sub> , NO <sub>x</sub>	Gas Detector Tube	Chemical Length-of-Stain	Yes
CAT-A-10	Particles by Size	Laser Particle Counter	Laser Particle Counter	Yes

‡ Trace Analytics, LLC certifies that the instrument(s) associated with the specified method were calibrated in accordance with applicable internal QA procedures.